

Certificate of Compliance

Certificate Number **20081027-E307997**
Report Reference **E307997, 2008 October 24**
Issue Date **2008 October 27**

Page 1 of 2



Issued to: **ELHAND TRANSFORMATORY**
UL. PCK 22
42-700 LUBLINIEC POLAND


This is to certify that representative samples of **COMPONENT - SYSTEMS, ELECTRICAL INSULATION**
Class 180(H) insulation system designated ELHAND 180-1

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL1446 - Systems of Insulating Materials - General, Sixth Edition

Additional Information: See Addendum for Ratings

Only those products bearing the UL Recognized Component Mark should be considered as being covered by UL's Recognition and Follow-Up Service.

The UL Recognized Component Mark generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions.

Look for the UL Recognized Component Mark on the product

Issued by:
Leigh Jansen, Project Engineer
Underwriters Laboratories Inc.

Reviewed by:
Sander Nieuwenhuijzen, Engineering Team Leader
Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number **20081027-E307997**
Report Reference **E307997, 2008 October 24**
Issue Date **2008 October 27**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

System Designation	Insulation Class	Maximum Hot Spot Temperature	Indoor	Outdoor (Enclosed)
ELHAND 180-1	180 H	180	Yes	Yes

Issued by:
Leigh Jansen, Project Engineer
Underwriters Laboratories Inc.

Reviewed by:
Sander Nieuwenhuijzen, Engineering Team Leader
Underwriters Laboratories Inc.